



**MADERA UNIFIED  
SCHOOL DISTRICT**  
1902 Howard Road  
Madera CA 93637  
(559) 675-4500  
(559) 675-1186 Fax  
[www.madera.k12.ca.us](http://www.madera.k12.ca.us)

**Board of Trustees:**

President:  
Ed McIntyre

Clerk:  
Ray G. Seibert

Trustees:  
Ricardo Arredondo  
Brent Fernandes  
Philip Huerta  
Ruben Mendoza

**SUPERINTENDENT:**  
**Todd Lile**

December 6<sup>th</sup>, 2018

Addendum No. 1

Bid No.090118

Installation of New Fire Alarm System at Adams Elementary School

**NOTICE TO ALL VENDORS:**

This Addendum is attached to and made a part of the above entitled specifications for Madera Unified School District for Bid No.090118 with a Bid due date of December 14, 2018 @ 9:00 am

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.

Questions/Clarifications:

**Questions due no later than December 7, 2018 @ ~~10:00 am~~ 3:00 pm**

1. What are the work hours?  
**2:30pm-10:30pm-Contractor may work during school hours if work being performed is on the roof, contractor must co-ordinate with the Director of Maintenance and Operations prior.**
2. What days is the District closed?-**December 24<sup>th</sup>, 25<sup>th</sup> & 31<sup>st</sup> and January 1<sup>st</sup>.**
3. What is the timeline for completion? **50 workdays after notice to proceed.**
4. Will new conduit need to be installed underground? **Yes**
5. What type of material is to be used for exposed areas of wiring (Office and Cafeteria)? **Electrical Metallic Tubing (EMT)**
6. Is the contractor responsible for painting the Conduit? **No**
7. What is acceptable if there is no attic space? **If no attic space is available exposed wire is okay above the t-bar ceiling**
8. Is it acceptable to run wiring above or below? **Yes, contractor can decide how to run, they need to notify the Director M & O for approval.**
9. Can a contractor come back for an additional job walk-**Yes, they need to arrange with the Director of M & O**
10. Who's responsible for repairing any grass areas? **The District**
11. Who fills any concrete that is saw cut? **The contractor is responsible to pour back any concrete that is needed.**

12. Who supplies the materials? **A list of materials has been provided by the District as part of the Bid Documents. All specialty cable/conduit and any materials needed to complete the work not provided by the District is the responsibility of the contractor.**
13. How will the transition from the old system to the new system be sequenced? **A timeline of activities will be coordinated between the District and the contractor. All FA testing will need to be done after school is out for the day. The District will be responsible for fire watch during the switchover.**
14. Can you confirm the required bid docs to be included with bid forms? Not all items in bid docs appear to be applicable (see fingerprinting docs). Also, is non-collusion affidavit the only item that requires notary? **All forms that are part of the bid document must be submitted. Since the contractor may work during school hours, then yes, the fingerprinting form is required. Awarded vendor will be required to submit a Performance and Payment Bonds along with Insurance Certificates, these items will require notary.**

Signature: \_\_\_\_\_

Date: \_\_\_\_\_