

Madera Unified **School District**

March 23, 2023

Addendum No.1 Bid No.031423-MSHS Tennis Court Project

NOTICE TO ALL VENDORS:

This addendum is attached to and made a part of the above-entitled specifications for Madera Unified School District for Bid No.031423-MSHS Tennis Court Project with a due date of March 28, 2023 @ 10:00:00 AM.

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.

1.Would the District Accept a class "A" License? Yes

2. Would the contractor be allowed to remove and replace 2 panels of the fence panels to allow trucks to get in and out? Yes

3. Can you confirm that concrete is supposed to be poured back 5" thick per the concrete tennis court specs? Yes correct, pour back 5" thick

Signature: _____

Date: _____

Todd Lile Superintendent Board of Trustees Ruben Mendoza, Clerk Lucy Salazar, President

Nadeem Ahmad

Israel Cortes Gladys A. Diebert Joetta Fleak Ray G. Seibert

