

1902 Howard Road, Madera, CA 93637 559.675.4500 Fax: 559.675.1186 www.madera.k12.ca.us

February 21, 2024

See attached:

Addendum No. 2 Bid No.020624A-MSHS Varsity Baseball Scoreboard

NOTICE TO ALL VENDORS:

This addendum is attached to and made a part of the above-entitled specifications for Madera Unified School District for Bid No. 020624A-MSHS Varsity Baseball Scoreboard, with a bid turn in date of February 27, 2024 @ 11:00:00 am

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.

Signature:		
	Signature:	
	Jigriature	
Date:	-	
Date:		
Jaio	late:	
	2410	



(559) 449-8444 OFFICE (559) 449-8404 FAX info@brooksransom.com EMAIL brooksransom.com WEBSITE

Scott Carter, CE | Gaylord "Rick" Ransom, SE, CE | Arturo Lopez | Nathan Miller, SE, CE | Klare Yavasile, SE, CE | Eric Bain, CE | Dioseline Garcia-Padron, CE

7415 N. Palm Ave., Ste. 100 Fresno, CA 93711

Bid No. 020624A MSHS Varsity Scoreboard Project Addendum No. 2

Date: February 20, 2024

Baseball Scoreboard

Madera South High School

DSA Application Number: 02-121895

Madera Unified School District

Madera, CA

BRA Project No. 23314



NOTICE TO ALL CONTRACTORS SUBMITTING BIDS FOR THIS WORK AND TO ALL PLAN HOLDERS:

You are hereby notified of the following changes, clarifications or modifications to the original Contract Documents, Project Manual, Drawings, Specifications, and subsequent Addenda. This Addendum shall supersede the original Contract Documents and previous Addenda wherein It contradicts the same and shall take precedence over anything to the contrary therein. All other conditions remain unchanged.

INDEX OF ADDENDA TRASNMITTED HEREWITH

AD2-1:

Sheet C-1: In AD1-2 replace deleted note 2 with:

1. The scoreboard will be furnished by the owner.

AD2-2:

Sheet C-1: In General Notes:

1. In note 3, revise "Paint Exposed Steel." to See "Structural Steel and Welding" notes on sheet SB0.2 note 15 for hot dipped galvanized finish information.

AD2-3:

Sheet SB0.2: In Structural Steel and Welding notes:

1. In note 15, omit following "or painted with zinc-rich primer, undercoat, and finish coat; or equivalent paint system.".

STRUCTURAL ENGINEERS ASSOCIATION
AMERICAN COUNCIL OF ENGINEERING COMPANIES
AMERICAN SOCIETY OF CIVIL ENGINEERS
EARTHOUAKE ENGINEERING RESEARCH INSTITUTE
INTERNATIONAL CODE COUNCIL