



**MADERA UNIFIED
SCHOOL DISTRICT**
1902 Howard Road
Madera CA 93637
(559) 675-4500
(559) 675-1186 Fax
www.madera.k12.ca.us

Board of Trustees:

President:

Ed McIntyre

Clerk:

Ray G. Seibert

Trustees:

Ricardo Arredondo

Brent Fernandes

Philip Huerta

Ruben Mendoza

SUPERINTENDENT:

Todd Lile

December 11, 2018

Addendum No. 3

Bid No.090118

Installation of New Fire Alarm System at Adams Elementary School

NOTICE TO ALL VENDORS:

This Addendum is attached to and made a part of the above entitled specifications for Madera Unified School District for Bid No.090118 with a Bid due date of **December 18, 2018 @ 10:30 am**

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.

Questions/Clarifications:

1. Clarify the Fingerprinting requirements?

The forms in the Bid Doc have a strike through for fingerprinting since the contractor will be working when students are not present. Please sign and submit the portion of the form that shows "exempt from finger printing".

2. The contact documents/Addendum 1 indicated that the District will be providing a list of equipment that will be provided by the district, What does the equipment consist of ? **Please see attached list.**
3. Will Madera USD be supplying the cabling for the fire alarm system on this project? Please clarify scope of work? **All cabling and /or electrical wire is by the contractor**
4. Will new conduit need to be installed underground? **Yes**
5. Pursuant to Madera USD Board Bylaws (9270) – "Board members, employees, or district consultants shall not be financially interested in any contract made by the Board on behalf of the district, including in the development, preliminary discussions, negotiations, compromises, planning, reasoning, and specifications and solicitations for bids. If a Board member has such a financial interest in a contract made by the Board, the contract is void. (Government Code 1090). Is legal for a contractor (EKC – a gamewell authorized dealer/installer) to bid on public work projects (John Adams Elem fire alarm) that that contractor designed or acted As the design consultant (EKC as shown on all drawings and indicated at the job walk) ? **EKC was there as a representative for the project.**

Addendum No.3 cont.

6. Is it a requirement for the installation Contractor to be an authorized dealer of the Fire Alarm Manufacturer? **No, just need to have the proper contractor's license.**

Signature: _____

Date: _____

Equipment List

Bid No.090118-Installation of New Fire Alarm System at Adams Elementary School

EKC GAMEWELL E3 FIRE ALARM SYSTEM

Mfg. Part#: MUSD-GAMEWELL

MUSD-Gamewell Solution:

1x Gamewell E3 Series Fire Alarm
Panel

4x 12 volt 7 Amp Hour Batteries

1x DACT E3 ALARM COMMUNICATOR

1x HPFF8 POWER SUPPLY

1x AOM-2SF CONTROL MODULE

105x ASD-PL2F ADDRESSABLE SMOKE DET

84x ATD-HL2F ADDRESSABLE HEAT DET

18x MSC-COF ADDRESSABLE M-C DET

208x B210LP DETECTOR BASE

1x INX FIRE ALARM VOICE TRANSPONDER

11x OUTDOOR SPEAKERS, WALL MT RED

1x CEILING MOUNT STROBE RED

66x SPEAKER/STROBE CEILING MT. RED

5x SPEAKER/STROBE WALL MT. RED

5x MS-7ASF MANUAL PULL STATIONS

1x AOM-2RF RELAY MODULE

1x LOC ALARM PANEL

CALSAVE CONTRACT # 527683

Contract: MARKET