

ADDENDUM NO.05

DATE: 11/04/21

PROJECT:

'Matilda Torres High School, Toros Stadium'
Matilda Torres High School
16645 Road 26. Madera, CA 93638

OWNER:

Madera Unified School District
1902 Howard Road
Madera, CA 93637-5123

ARCHITECT:

DARDEN ARCHITECTS, INC.
Attention: Matthew Heiss
6790 N. West Avenue
Fresno, California 93711
T. (559) 448-8051
F. (559) 446-1765

DARDEN PROJECT NO. 0622.4
DSA File Nos. 10-C3
DSA APPL. NO. 02-118396

It will be the responsibility of the General Contractor to submit the information contained in this addendum to all its subcontractors and suppliers. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

The following additions, deletions, and revisions to the SHEETS and Project Manual are hereby made and do become a part of these Contract Documents.

INDEX OF ADDENDA TRANSMITTED HEREWITH

PROJECT MANUAL:

SPECIFICATIONS:

CHANGES TO SPECIFICATIONS AD5-SP01

SHEETS:

CHANGES TO SHEETS:

ARCHITECTURALAD5-A01 thru AD5-A03

ATTACHMENTS:

DOCUMENTS OR SPECIFICATIONS:

Saleh Pre Bid RFI -001

SHEETS:

N/A

PROJECT MANUAL:

SPECIFICATIONS:

CHANGES TO SPECIFICATIONS:

AD5-SP01 Refer to Specification Section 099100

1. Refer to Part 3.7, Paragraph G

a. Delete paint system X-19 From project, Paint type not used.

CHANGES TO DRAWINGS:

LANDSCAPE:

AD5-A01 Refer to sheet X/A201

1. See Interior finish schedule – Building Q
 - a. under column titled METAL DECK, Metal Deck and Steel Beams, replace all references to paint type X-19 in schedule to paint type X-20

AD5-A02 Refer to sheet Q/A101

1. See floor plan A10
 - a. Replace paint type X19 with X-20 in notes describing Hatch and required fire rating

AD5-03 Refer to addenda 4 Pre Bid RFI log

**Append Pre Bid RFI log issued in addenda 4 with attached response to Saleh RFI 01-
intumescent Paint**

END OF ADDENDUM NO. 05

REQUEST FOR INFORMATION

RFI No.: Saleh 01

To: **Darden Architects, Inc.**
6790 North West Avenue
Fresno, California 93711

Date: 11/4/2021

Respond By:

Architect Project No.

Project:

Attn: **Matt Heiss**

INFORMATION REQUESTED: INTUMESCENT Paint Clarification

The finish schedule and Q/A101 show X-19 as an intumescent system but specs show this as a clear lacquer finish for steel.

Q/A102, Q/A202 and the painting spec shows X-20 as an intumescent system.

Is the intent to use system X-20 not X-19?

Cost Impact: None:

Signature: _____

Schedule Impact: None:

_____ Days

Pages Attached: _____

Trade/Contractor: _____

Schedule Task No/Item: _____

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in the Contract Sum or Contract Time. Proceeding with the Work in accordance with these instructions indicates your acknowledgement that there will be no change in the Contract Sum or Contract Time.

If the Contractor considers that this supplemental instruction requires a change in the Contract Sum or Contract Time, the Contractor shall not proceed with this Work and shall promptly submit an itemized proposal to the Architect for doing this work. If your proposal is found to be satisfactory and in order, this supplemental instruction will be superseded by a Construction Change Directive.

Referred To:

Referred Date:

Return Date:

SUPPLEMENTAL INSTRUCTIONS:

X-19 Paint system not in project.

Replace all references to X-19 paint system in drawings with X-20.

See addenda 5 for formal response

Consultant's Signature: _____

Architect's Signature: _____

Date: _____

Date: _____

Copy: ☐ Owner ☐ Inspector ☐ Testing Lab ☐ Structural ☐ Mech. ☐ Elec ☐ File ☐ Other Pages Attached: _____