



May 12, 2020

Addendum No.4
Bid No.040720-Asphalt Resurface & Repair Projects at Various School Sites

NOTICE TO ALL VENDORS:

This Addendum is attached to and made a part of the above-entitled specifications for Madera Unified School District for Bid No.040720-Asphalt Resurface & Repair Projects at Various School Site, with a due date of May 6, 19, 2020 @ 10:01 a.m.

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.
Questions/Clarifications:

Clarifications:

La Vina:

~~1. Install a 3'x435' valley gutter.~~

Please confirm if we would be adding a new concrete v-gutter at La Vina and if so the specs for that. **No v-gutter will be installed as part of contract.**

Questions:

In the pavement sections listed in the specifications and Addendum No. 2, the Parking Lot and Playground Area sections are described as follows: "Installation of 3" hot asphalt in 1 lift over 6" compacted native subgrade base..."

Please clarify if the pavement sections should be: 3" of new hot asphalt over 6" of new base rock OR 3" of new hot asphalt over 6" of existing, compacted subgrade?

3" New asphalt over existing compacted subgrade

Date_____

Signature_____