

Bid No.030119-Installation of New Fire Alarm System at Adams Elementary School

Equipment List: The District will be providing the equipment listed below. The contractor is responsible for any additional equipment needed to complete the project.

EKC GAMEWELL E3 FIRE ALARM SYSTEM

Mfg. Part#: MUSD-GAMEWELL

MUSD-Gamewell Solution:

1x Gamewell E3 Series Fire Alarm  
Panel

4x 12 volt 7 Amp Hour Batteries

1x DACT E3 ALARM COMMUNICATOR

1x HPFF8 POWER SUPPLY

1x AOM-2SF CONTROL MODULE

105x ASD-PL2F ADDRESSABLE SMOKE DET

84x ATD-HL2F ADDRESSABLE HEAT DET

18x MSC-COF ADDRESSABLE M-C DET

208x B210LP DETECTOR BASE

1x INX FIRE ALARM VOICE TRANSPONDER

11x OUTDOOR SPEAKERS, WALL MT RED

1x CEILING MOUNT STROBE RED

66x SPEAKER/STROBE CEILING MT. RED

5x SPEAKER/STROBE WALL MT. RED

5x MS-7ASF MANUAL PULL STATIONS

1x AOM-2RF RELAY MODULE

1x LOC ALARM PANEL

CALSAVE CONTRACT # 527683

Contract: MARKET